

Legal Services
Business Services Company
10 South Dearborn Street, 49th Floor
Chicago, IL 60603

Writer's Direct Contact Information
Direct Dial: (312) 394-5831
E-mail: michael.pabian@exeloncorp.com

June 2, 2008

Via Electronic Mail

Judge Claudia Sainsot
Illinois Commerce Commission

Re: ICC Docket No. 06-0525, Briefs on Exception of ELPC/Illinois Attorney General's Office
and the City of Chicago.

Dear Judge Sainsot:

Commonwealth Edison Company believes that it is necessary to correct two items for the record.

In their brief on exceptions, ELPC and the Illinois Attorney General's Office included a report from NREL on Utility Accessible Disconnect switches, which indicates (on p.16) that ComEd does not require those devices for generators smaller than 40 kW. That is not true. ComEd does require them even for the small generators.

In its brief, the City of Chicago represents (on p. 6) that ComEd allowed the connection of a "CHP" of the Museum of Science and Industry to an "Area Network Grid". The "Area Network Grid" in that situation was not an "area network" at normal secondary distribution voltage. It was a special network at primary voltage with special protective equipment that would not have been involved in the expedited Level 1-3 process that are being discussed in the proposed rules.

It is unfortunate that these issues are being brought up now, instead of in the original comment round.

Thank you.



Michael S. Pabian
Attorney for Commonwealth Edison Company

cc: All parties of record via e-mail